



No.F6/DFS/MS/School/SZ/2025/131

Dated: 10/02/2025

FIRE SAFETY CERTIFICATE

Certified that the **Satyawati Sood Arya Girls Sr. Sec. School** located at **Nizamuddin East, New Delhi-13**, comprised of Two Blocks: **A Block** - Ground + 02 upper floors & **B Block** - Ground + 01 upper floor was granted Fire Safety Certificate by this department vide letter no.- F.6/DFS/MS/School/2022/SZ/56 dated 21.01.2022. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 01.02.2025 in the presence of Mrs. Meenakshi Sethi (HOS) and found that the school building has complied with the fire prevention and fire safety requirements in accordance with the circular no. 3298 to 3398 dated 01.03.2011 issued by the Directorate of Education and the building/premises comprised of Two Blocks: (**A & B Block**) is fit for occupancy of Group B "**Educational Building**" upto first floor with effect from10/02/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on.....10/02/2025 at New Delhi by


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Satyawati Sood Arya Girls Sr. Sec. School located at Nizamuddin East, New Delhi-13.

Conditions for the validity of Fire Safety Certificate

1. **This Fire Safety Certificate is valid for Ground + 01 upper floor each block.**
2. Second floor of A block shall not be used.
3. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
9. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

Received
on
8/2/2025/734
10/02/2025